OFFICE OF THE SUPERINTENDENT, POWER AND LIGHTING, MYSORE.

Notification dated the 20th August 1937.

Sealed tenders, in triplicate, will be received at the office of the Superintendent, Power and Lighting, Mysore.

Tenders should be superscribed with the name of the work given below.

2. The plan may be seen in the office of the undersigned at all working hours.

3. The tenders should be drawn up in conformity with the detailed specification furnished, at the same time writing out the rates at which each item of work will be executed in figures as well as in words, failing which no cognisance will be taken of the tender.

4. The undersigned reserves the right to reject the tenders without assigning any reason therefor.

5. The successful tenderer will be required to deposit with the undersigned an earnest money of rupees thirty only (Rs. 30) and execute an agreement within three days from the date of receipt of information as to the acceptance of the tender, failing which the tender will be disposed of otherwise.

6. Materials to be used on the work should be of best quality English or American Manufacture and conform to the specifications.

7. The teakwood planks to be used for boards and other purposes should be free from cracks and knots and well seasoned. No planks less than 12″ in width should be used for boards (front or rear) unless it is to make up the difference in size of the boards required. In all such cases, lap joints should be adopted.

8. The wiring in general should be executed strictly in accordance with the wiring rules of this Department as well as that of Institution of Electrical Engineers.

9. No item other than those noted in the statement below should be included in the tender, as the items include provision for all sundries, masonry repairs and painting the exterior of the lead cables and other parts of the wiring to suit the surroundings, etc.

10. The control switches are required to be grouped wherever necessary. The successful tenderer should carry out any small deviations in the location of the lighting and other fixtures, switch points, etc., not affecting the estimate materially without any extra cost. The undersigned reserves the right to reject the work in full or portion of it if he finds the work not executed satisfactorily in terms of the specifications.

11. *Name of work.*—"Installing Electric Lights, etc., to Kasi Viswesvaraswamy Temple, Gosayi Ghatta, Ganjam."

12. Last date and time for receiving the tenders is 10th September 1937, at 3 P.M.

13. Time and date for opening the tenders in public is at 4-30 P.M. on 10th September 1937.

14. The time allowed for completion of the work is 3 weeks (Three Weeks) from the date of acceptance of the tender, failing which a penalty of rupee one (Re. 1) for each day's delay over and above the stipulated time will be enforced.

15. Details of work.—

1.	Supplying and fixing rails 24 feet long and tarring the same ..	3 (Three)
2.	Do 2- pin double cross arms, complete with bolts, clamps, etc., and tarring the same	4 (Four)
3.	Do Insulators and Pins	16 (Sixteen)
4.	Do Guy sets, complete with anchor rod, 7 strand guy wire and 6 feet of 2″ glvd. guard pipe	3 (Three)
5.	Supplying and stringing bare copper wire No. 8 B. & S.	29 lbs. (Twenty-nine).
6.	Supplying and running mains in ¾″ W.I. pipe with necessary accessories, bends, 3 sets of clamps, etc., using No. 10 B. & S. insulated wire ..	50′ (Fifty)
7.	Do sub-mains in ½″ W.I. pipe with necessary angle iron, supports, bends, clamps, etc., using No. 12 B. & S. insulated wire and accessories	125′ (One hundred and Twenty-five).
8.	Supplying, fixing and wiring T. W. Board 21″×18″×1″ with 2″×1″ battens and rear board, equipping it with a 15 amp. D.P. iron-clad switch with fuses, one 3-way 10 amp. per way D.P.H.O. Pattern "Neata" Distribution Board with 5 amp. bakelite circuit switch G.E.C. Cat. No. S. 25, using No. 10 and 14 B. & S. insulated wires and accessories	1 (One)
9.	Earthing mains and sub-mains piping lead covered and steel armoured cables, iron-clad switches, etc.	Item.

10.	Supplying, fixing and wiring in twin and triple conductor lead covered No. 14 B. & S. Cable, run on suitable T.W. fillets, for drop lights, complete with bakelite ceiling rose, flexible cord, B.C.C.G. bakelite lamp holder, 5 amp. bakelite control switch, etc., using universal metal junction boxes, link clips, lead plugs and accessories ..	10 (Ten)
11.	Do do do as per specification above for oxidised copper brackets 6" $\times \frac{1}{2}$", with lamp holder (bakelite), 5 amp. control switch, etc.	4 (Four)
12.	Do do for C. I. bulk head fittings complete with B.C. lamp holders, 5 amp. control switch, etc.	4 (Four)
13.	Do do for bakelite B.C. lamp holders, back-plate type, 5 amp. control switch, etc.	3 (Three)
14.	Do do for "Terrace Fitting" G.E.C. Cat. No. Z5335, with B.C. lamp holder, angle iron bracket, 5 amp. control switch, etc.	2 (Two)
15.	Supplying and fixing shades, tin-enamelled 10"	17 (Seventeen)
16.	Do do lamps, 230 volts, B.C. 200 Watts, gas-filled ..	2 (Two)
17.	Do do 230 volts B.C., 20 to 60 Watts.	21 (Twenty one).
18.	Supplying and laying No. 12 B. & S. twin conductor, paper insulated, lead covered, double steel tape armoured, jute served underground cable in a trench 3 feet deep surrounding the cable with 3" of fine sand, enclosing the two ends of the cable in in-door and pole type cast iron junction boxes filled with insulating compound and protecting the vertical run of the cable on pole in 18 feet of $1\frac{1}{2}$" glvd. pipe with 2 bends supported with iron clamps with the pole, using No. 12 B. & S. insulated wire and accessories	100' (Hundred feet).
19.	Supplying and fixing on the S. M. Rail and wiring lamp fittings, complete with goose-neck, Aluminium hood, Radial Wave Reflector, B. C. lamp holder, 5 amp. bakelite control switch, 60 watts, 230 volts, gas-filled B. C. lamp, etc., using No. 14 B. & S. insulated wire and accessories	2 (Two)
20.	Supplying, fixing and wiring a pair fuse cut-outs and a 5 amp. D. P. linked switch on suitable T. W. Block, using necessary accessories	5 (Five)

M. HAYATH,
Superintendent.

6 G

MYSORE DASARA EXHIBITION, 1937

5th October to 20th October 1937.

Best place to learn new methods and earn more. Just the place to advertise with profit to yourself and benefit to others.

Participate in the EXHIBITION, and invigorate AGRICULTURE, INDUSTRY and TRADE

Large numbers of buying public from all parts of India will be visiting **MYSORE** during the Mysore Dasara Exhibition.

☞ *All Facilities will be given to Exhibitors*

A HANDBOOK and GUIDE to the

EXHIBITION

in **English** will be issued and will command an extensive sale as in previous years. There is space in it for only a limited number of

ADVERTISEMENTS.

For Prospectus, Advertisement Rates, etc., please write to :—

THE SECRETARY,
Mysore Dasara Exhibition Committee,
MYSORE.

or

S. S. RAJAN, Esq.,
Advertising Consultant,
Shahibagh House, Ballard Estate,
BOMBAY
for Advertisements outside the Mysore State.

Printed by the Superintendent at the Government Press, Bangalore—1937